

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam – 631002

Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com


Ref: Collector, VLR Lr. No. ந.க.அ.6/31531/2013 Dated : 23.09.2015

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL
STATEMENT ACCOMPANYING FORM - A

1. Name of the School and Door no of the Building : **VEDAVALLI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY SCHOOL**
Thirumalai Nagar, Sipcot – Vanapadi Road, Vanapadi Village, Walajah Taluk, Ranipet District – 632 403.
2. Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S.F.No. 272/3A1, Thirumalai Nagar, Sipcot – Vanapadi Road, Vanapadi Village, Walajah Panchayat Union, Walajah Taluk, Ranipet District – 632 403.
3. Year of construction : Vide Annexure- II
4. Approximates cost of construction as per current rate : Rs. 223.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational
6. Purpose for which the building has hitherto been used : Educational
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under
(i) Foundation : RCC Column & Footing
(ii) Basement : RCC Column, Plinth Beam & Brick in CM
(iii) Superstructure : RCC Column & Brick in CM
(iv) Floor & Roof are to be given : Flooring: Cement & Ceramic Tiles
Roof: RCC Slab, Mangalore Tiled & AC Sheet lean to roof
8. Period for which the license is require : May be issued FROM **01.06.2026 to 31.05.2029**
(For Three years only)
9. Number of persons to be accommodated Refer "ANNEXURE" to this : **One Thousand Five Hundred Fifty (1550) Pupils only**

Place : Arakkonam

Date : 20-05-2026


Signature of the Correspondent


Signature of the Engineer
Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.



மழை பெறுவோம்

ANNEXURE TO "STATEMENT ACCOMPANYING FORM – A"

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched buildings are used for conducting any classes within the School premises. Any thatched building constructed/used after issue of this certificate, I would be held responsible for fire accident/mishap that may occur later and that I am aware that it is a punishable crime.


Signature of the Correspondent

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam - 631002
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

ANNEURE - II

VEDAVALLI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY
SCHOOL, VANAPADI VILLAGE

Sl.No.	Name of the Building	Year of Construction	Age of the Building
1.	MAIN BUILDING : Ground Floor : RCC First Floor : RCC Second Floor : RCC Ground Floor : Mangalore Tiled (Dining Hall) Cycle Shed : AC Sheet	2003 2004 2007 2007 2006	23 Years 22 Years 19 Years 19 Years 20 Years
2.	AKSHAYABLOCK : Ground Floor : RCC First Floor : RCC Second Floor : RCC	2010 2010 2014	16 Years 16 Years 12 Years


Er. D. NATARAJAN, B.E.,(CIVIL) M.E.
Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam – 631002
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM – B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS
VEDAVALLI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY
SCHOOL, VANAPADI VILLAGE

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER TAMILNADU COMBINED DEVELOPMENT AND BUILDING RULES 2019.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.


1. **Foundation:**

- i. **Depth below ground level** : 06 ft below G.L
ii. **Nature of soil met out in the foundation** : Hard Gravelly Soil
iii. **Pressure at foundation** : Within the Permissible Limit
iv. **Probable safe bearing capacity of the foundation** : 20 tones / Sq.m

2. **Superstructure:**

- i. **Maximum stress in most critical** a) R.C.C Concrete: Within the Permissible limit
Sections of masonry and concrete b) Masonry : Within the Permissible limit
ii. **Nature of masonry and concrete** : Brick masonry in cm: 30 tones / Sq.m.
And its safe permissible stress R.C.C : 40 Kg / Sq.cm.

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 01.06.2026 to 31.05.2029.


Signature of the Correspondent


Signature of the Engineer
Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam – 631002

Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM – C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS


**EDAVALLI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY
SCHOOL, VANAPADI VILLAGE**

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER TAMILNADU COMBINED DEVELOPMENT AND BUILDING RULES 2019.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
VEDAVALLI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY SCHOOL Thirumalai Nagar, Sipcot- Vanapadi Road, Vanapadi Village, Walajah Taluk, Ranipet District – 632 403	<u>Vide Annexure -II</u>	Rs. 223.00 Lakhs	Ground Floor + 2	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational	License may be issued for the period of Three Years from 01.06.2026 to 31.05.2029	1550 Pupils only	Building is structurally sound


Signature of the Correspondent


Signature of the Engineer
Er. D. NATARAJAN, B.E.,(CIVIL) M.I.E.
Chartered Engineer
Panel Engineer
Vellore District
50A, 3rd Street,
S.S. Nagar, Palanipet,
Arakkonam-631 002
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res cum off : 50-A,3rd Street,
Somasundaram Nagar.
Palanipet,
Arakkonam – 631002
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM – E

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS
EDAVALI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY
SCHOOL, VANAPADI VILLAGE

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER TAMILNADU COMBINED
DEVELOPMENT AND BUILDING RULES 2019.

1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law. : Er. D.NATARAJAN, B.E. (CIVIL), M.I.E.
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMILNADU.
PANEL ENGINEER CLASS IA,
VELLORE DISTRICT
2. Location of the building inspected (Door Number, Street Number, Name of place, i.e. Municipal Corporation / Municipality / Panchayat or Panchayat Union/Township/Cantonment.) : S.F.No. 272/3A1, Thirumalai Nagar,
Sipcot – Vanapadi Road, Vanapadi Village,
Walajah Panchayat Union,
Walajah Taluk, Ranipet District – 632 403.
3. Date of Inspection : 20.05.2026
4. Purpose for which the building is used : Educational
5. Nature of defects noticed : No defects found
6. Suggestions for rectifying defects : Nil
7. If in a dangerous condition, immediate Steps recommended to be taken : Nil

Signature of the Engineer

Er. D. NATARAJAN, B.E.,(CIVIL) M.E.

Chartered Engineer

Panel Engineer

Vellore District

50A, 3rd Street,

S.S. Nagar, Palanipet,

Arakkonam-631 002

Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

BUILDING SAFETY CERTIFICATE

No. 08/PE-VELLORE

Dated : 20.05.2026

It is certified that the existing building **VEDAVALLI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY SCHOOL** at Thirumalai Nagar, Sipcot - Vanapadi Road, Vanapadi Village, Walajah Taluk, Ranipet District - 632 403, is having block (s) / Floors (s) as per details below :

Details of Block (s) in School	Block (1)	Block (2)	Block (3)
No. of Floor(s) in the Block	03 Nos.	03	-

This building is owned / occupied by **VEDAVALLI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY SCHOOL** Have complied with Building safety requirements in accordance with National Building Code Rules, and verified by the officers concerned of **Mr. D.NATARAJAN, B.E.**, on 20.05.2026 in the presence of **CORRESPONDENT, VEDAVALLI VIDYALAYA NURSERY & PRIMARY SENIOR SECONDARY SCHOOL** and that the building/premises is fit for occupancy for running school with effect from **01.06.2026 to 31.05.2029** for a period of **3 (Three) years** in accordance with rule and subject to compliance of the specific conditions as appended.

1. Periodical Inspection of School building must be ensured.
2. Time to time maintenance of the building to be taken care.

Issued on 20.05.2026 at Arakkonam by


 Signature of the Engineer
Er. D. NATARAJAN, B.E., (CIVIL) MIE
 Chartered Engineer
 Panel Engineer
 Vellore District
 # 50A, 3rd Street,
 S.S. Nagar, Palanipet,
 Arakkonam-631 002
 Cell: 94431 06470, 8056631312